

Town of Westerly/Westerly Public Schools  
Rhode Island

PURCHASING DEPARTMENT

Town Hall  
45 Broad Street  
Westerly, RI 02891  
TEL: (401) 348-2500  
www.WesterlyRI.gov



**RFQ 25-22**

**HVAC Roof Top Unit Replacement  
ADDENDUM NO. 1 – July 10, 2024**

To: All Known Bid Document Holders

The following items represent additional information provided, changes, amendments or clarifications to the Contract Bid Documents for the above referenced project:

**A non-mandatory pre-bid meeting was held at 10:00 a.m. on July 3, 2024 sign in sheet to follow.**

**Questions/Clarifications**

- 1. Addition to the specifications: provide a protective coating to be applied by the factory on the coils from salt air damage. Provide product information with your bid including warranty.
- 2. Integration with existing controls: the system is Honeywell software.

This addendum will form a part of the Contract Documents and modifies the original Bidding Documents dated June 26, 2024, as noted above. Acknowledge receipt of this Addendum in the space provided on the Bid Form and *return this document with your bid*. Failure to do so may subject the Bidder to disqualification.

The above clarifications and information do not warrant reissuance of portions of the Bid Documents (Specifications & Bid Form).

**Addendum No. 1:**

Received and Accepted By: \_\_\_\_\_ Contractor: \_\_\_\_\_

Signed By: \_\_\_\_\_

Dated: \_\_\_\_\_

**Eileen Cardillo**  
Purchasing Agent/Risk Manager  
Town of Westerly/Westerly Public Schools  
45 Broad St, Westerly, RI 02891  
Tel: (401) 348-2599 [ECardillo@westerlyri.gov](mailto:ECardillo@westerlyri.gov)

