

*Town of Westerly
Rhode Island*

PURCHASING DEPARTMENT



Town Hall
45 Broad Street
Westerly, RI 02891
TEL: (401) 348-2500
www.WesterlyRI.gov

RFQ 2022-033

Duct Cleaning Services

ADDENDUM NO. 2 – May 31, 2022

To: All Known Bid Document Holders

The following items represent additional information provided, changes, amendments or clarifications to the Contract Bid Documents for the above referenced project:

A mandatory pre-bid meeting was held on May 17, 2022 at 10:00 a.m.; sign in sheet to follow.

BIDDER QUESTIONS with RESPONSES:

1. Can the pricing for each school be a total and not broken down into five categories per Attachment B form?
A. YES, we will submit a new bid form as part of Addendum 2
2. Will the town be looking for alternate or option for access doors in exposed ductwork or is similar gauge metal plates acceptable?
A. YES, similar gauge plate that is removable and includes some type of gasket sealant is acceptable
3. Are the fan coils located on ground floor in classrooms with no duct work included in bid?
A. NO, this will be managed by the in-house team
4. Are the unit ventilator with ductwork in the ceiling included in bid?
A. YES, this is specified to be included in the SOW
5. Can the price sheet be scraped to just show lump sum per school?
 1. YES, see answer to question #1
6. During our site visit at State St school we notice a lot of duct work and a lot of AHU in attic spaces that all were running and no one seem to know about. Please confirm all the units and duct work are to be cleaned.
A. ALL AHU units and ductwork are to be cleaned
7. Please confirm that we are to use the general labor rate to perform all work. According to the wage scale this is \$33.55 plus \$26.15 for the fringes for a total of \$59.70
A. YES, the general labor rate is confirmed

8. Will the successful contractor have a maintenance person or inspector to inspect as we go?
 - A. The awarded contractor is responsible for the quality control of their work. Random quality audits will take place. Photographs confirming compliance are required in mandatory weekly progress reports.
9. Do we have access to the schools during A & B shifts to perform work?
 - A. YES, the work will be completed during the summer. However, there are camps at several locations and work performed will need to be scheduled one week in advance to confirm space availability.

Dunns Corners Elementary School – See HVAC equipment list A2

1. Can you verify how many air handling units there are and highlight on the floor plan what each one services ?
 - A. 2 (TWO) heated only gas units service the Media Center and Main Office
2. Can you verify how many bathroom exhaust systems are to be cleaned ?
 - A. See HVAC equipment list A2
3. Can you provide the location and total number of Fan Coils to be cleaned ?
 - A. NONE this is an electric heat building

Westerly Middle School School – See HVAC equipment list A2

1. Can you verify how many air handling units there are and highlight on the floor plan what each one services ?
 - A. See plans, to be verified by vendors take off
2. Can you verify how many bathroom exhaust systems are to be cleaned ?
 - A. See plans, to be verified by vendors take off
3. The drawings provided are blurry and show ceiling tiles, do you have a set of drawings available without the ceiling tiles ?
 - A. YES there should be full MEP without the RCP included in the as-builts
4. Can you provide the location and total number of Fan Coils to be cleaned ?
 - A. See plans, to be verified by vendors take off

Westerly High School – See HVAC equipment list A2

1. Does the Gym require plywood to be placed over the floor for use of a lift ?
 - A. NO for soft wheel lifts
2. Can you confirm which exhaust systems are to be included and the Exhaust Fan Number and what it services?
 - A. See plans, to be verified by vendors take off
3. Can you verify how many air handling units there are and highlight on the floor plan what each one services ?
 - A. See plans, to be verified by vendors take off
4. Can you provide the location and total number of Fan Coils to be cleaned ?
 - A. See plans, to be verified by vendors take off

Springbrook School – See HVAC equipment list A2

1. Can you verify how many air handling units there are and highlight on the floor plan what each one services ?
A. See HVAC equipment list A2
2. Can you verify how many bathroom exhaust systems are to be cleaned ?
A. See HVAC equipment list A2
3. Can you provide the location and total number of Fan Coils to be cleaned ?
A. See HVAC equipment list A2

Basic State Street School – See HVAC equipment list A2

1. Can you verify how many air handling units there are and highlight on the floor plan what each one services
A. See HVAC equipment list A2
2. Can you verify how many bathroom exhaust systems are to be cleaned
A. See HVAC equipment list A2
3. Can you provide the location and total number of Fan Coils to be cleaned ?
A. See HVAC equipment list A2

Transition Academy School

1. Can you verify how many air handling units there are and highlight on the floor plan what each one services ?
A. 1 (One)
2. Can you verify how many bathroom exhaust systems are to be cleaned ?
A. 1 (One)
3. Can you provide the location and total number of Fan Coils to be cleaned ?
A. NONE

General Questions -

1. Page 17 of the Bid Package requests Lnft Pricing – Lnft pricing can only be configured if we know the total lnft per building or per air handling unit. Can you provide the total LNFT for each building and each AHU
A. We are looking for a unit price as listed on the bid form
 2. Page 17 of the Bid Package requests Register Cleaning pricing. Can you provide the total number of register's that are to be cleaned ?
A. List as a unit price
 3. Page 2 of the Bod Package requires Prevailing Wage Rates. It was agreed that all bidders would use general labor rate. Can you provide a copy of the prevailing wages and specify which Labor Category we are to use ?
A. Answered above
 4. Please confirm that Transition School only has 1 unit and 1 exhaust fan with less than 80' of duct work.
A. Confirmed
- CLARIFICATION-DEPENDING ON THE COST OF THE TOTAL PROJECT WPS RESERVES THE RIGHTING TO POTENTIAL REMOVE CERTAIN BUILDINGS FROM THE SCOPE OF WORK

This addendum will form a part of the Contract Documents and modifies the original Bidding Documents dated May 10, 2022, as noted above. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

The above clarifications and information do not warrant reissuance of any portions of the Bid Documents (including Bid Form).

Addendum No.2:

Received and Accepted By: Contractor: _____

Signed By: _____

Dated: _____

Eileen Cardillo
Purchasing Agent/Risk Manager
Town of Westerly/Westerly Public Schools
45 Broad St
Westerly, RI 02891
Tel: (401) 348-2599
Email: ECardillo@westerlyri.gov
www.WesterlyRI.gov

| ATTACHMENT A2 EQUIPMENT LIST | | | | | | |
|------------------------------|-------------------------------|--------|------------------|----------------------|---------------------------|--|
| Client Name | Building Name | Tag # | Description | Type Desc | Subtype Desc | |
| Westerly Public Schools | Babcock Hall-5305 | 304204 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General | |
| Westerly Public Schools | Babcock Hall-5305 | 304220 | ACCU-4 | Air Conditioner Pkg | Condensing Unit General | |
| Westerly Public Schools | Babcock Hall-5305 | 304205 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General | |
| Westerly Public Schools | Babcock Hall-5305 | 304206 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General | |
| Westerly Public Schools | Babcock Hall-5305 | 304218 | ACCU-6 | Air Conditioner Pkg | Condensing Unit General | |
| Westerly Public Schools | Babcock Hall-5305 | 304219 | ACCU-5 | Air Conditioner Pkg | Condensing Unit General | |
| Westerly Public Schools | Babcock Hall-5305 | 304210 | HVM Pent Exhaust | Air Dist Ventilation | Fan Centrif Exhaust>10HP | |
| Westerly Public Schools | Babcock Hall-5305 | 304208 | Exhaust Fan | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |
| Westerly Public Schools | Babcock Hall-5305 | 304211 | EF-3 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |
| Westerly Public Schools | Babcock Hall-5305 | 304212 | Exhaust Fan | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |
| Westerly Public Schools | Babcock Hall-5305 | 304213 | Exhaust Fan | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |
| Westerly Public Schools | Babcock Hall-5305 | 304214 | EF-1 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |
| Westerly Public Schools | Babcock Hall-5305 | 304216 | EF-15 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |
| Westerly Public Schools | Babcock Hall-5305 | 304217 | Exhaust Fan | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |
| Westerly Public Schools | Babcock Hall-5305 | 304221 | Exhaust Fan | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |
| Westerly Public Schools | Babcock Hall-5305 | 304222 | Exhaust Fan | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |
| Westerly Public Schools | Babcock Hall-5305 | 304079 | Exhaust Fan | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |
| Westerly Public Schools | Dunn's Corner Elementary-5305 | 304080 | Exhaust Fan | Air Dist Ventilation | Fan Centrif Exhaust 0-1HP | |
| Westerly Public Schools | Dunn's Corner Elementary-5305 | 304081 | Exhaust Fan | Air Dist Ventilation | Fan Centrif Exhaust 0-1HP | |
| Westerly Public Schools | Dunn's Corner Elementary-5305 | 304082 | Exhaust Fan | Air Dist Ventilation | Fan Centrif Exhaust 0-1HP | |
| Westerly Public Schools | Dunn's Corner Elementary-5305 | 304083 | Exhaust Fan | Air Dist Ventilation | Fan Centrif Exhaust 0-1HP | |
| Westerly Public Schools | Dunn's Corner Elementary-5305 | 304084 | Exhaust Fan | Air Dist Ventilation | Fan Centrif Exhaust 0-1HP | |
| Westerly Public Schools | Dunn's Corner Elementary-5305 | 304085 | Exhaust Fan | Air Dist Ventilation | Fan Centrif Exhaust 0-1HP | |
| Westerly Public Schools | Dunn's Corner Elementary-5305 | 304108 | AHU | Air Dist Ventilation | AHU Hot Deck | |
| Westerly Public Schools | Spring Brook Elementary-5305 | 304099 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General | |
| Westerly Public Schools | Spring Brook Elementary-5305 | 304102 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General | |
| Westerly Public Schools | Spring Brook Elementary-5305 | 304109 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General | |
| Westerly Public Schools | Spring Brook Elementary-5305 | 304110 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General | |
| Westerly Public Schools | Spring Brook Elementary-5305 | 304096 | Exhaust Fan | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |
| Westerly Public Schools | Spring Brook Elementary-5305 | 304097 | Exhaust Fan | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |
| Westerly Public Schools | Spring Brook Elementary-5305 | 304098 | Exhaust Fan | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |
| Westerly Public Schools | Spring Brook Elementary-5305 | 304100 | Exhaust Fan | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |
| Westerly Public Schools | Spring Brook Elementary-5305 | 304101 | Exhaust Fan | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |
| Westerly Public Schools | Spring Brook Elementary-5305 | 304103 | Exhaust Fan | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |
| Westerly Public Schools | Spring Brook Elementary-5305 | 304104 | Exhaust Fan | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |
| Westerly Public Schools | Spring Brook Elementary-5305 | 304105 | Exhaust Fan | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |
| Westerly Public Schools | Spring Brook Elementary-5305 | 304106 | Exhaust Fan | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |
| Westerly Public Schools | Spring Brook Elementary-5305 | 304107 | Exhaust Fan | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |
| Westerly Public Schools | Spring Brook Elementary-5305 | 304113 | EF-16 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP | |

| Client Name | Building Name | Tag # | Description | Type Desc | Subtype Desc |
|-------------------------|------------------------------|--------|-------------------------|----------------------|-------------------------|
| Westerly Public Schools | Spring Brook Elementary-5305 | 304114 | EF-18 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Spring Brook Elementary-5305 | 304115 | EF-24 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Spring Brook Elementary-5305 | 304116 | Exhaust Fan | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Spring Brook Elementary-5305 | 304117 | EF-26 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | State St Elementary-5305 | 304237 | AHU Rm 1+3 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | State St Elementary-5305 | 304232 | AHU Rm 7 + 9 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | State St Elementary-5305 | 304233 | AHU Rm 7 + 9 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | State St Elementary-5305 | 304234 | AHU Rm 4+6 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | State St Elementary-5305 | 304235 | AHU Rm 4+6 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | State St Elementary-5305 | 304236 | AHU Rm 1+3 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | State St Elementary-5305 | 303934 | AHU Rm 14+15 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | State St Elementary-5305 | 303935 | AHU Rm 14+15 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | State St Elementary-5305 | 304239 | AHU 16+17 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | State St Elementary-5305 | 304240 | Kindergarten Closet | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | State St Elementary-5305 | 304241 | AHU Rm 11+12 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | State St Elementary-5305 | 304242 | AHU Rm 18+19 Girls Room | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | State St Elementary-5305 | 304243 | AHU Rm 18+19 Girls Room | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | State St Elementary-5305 | 304244 | AHU Rm 12-13 Girls Room | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | State St Elementary-5305 | 304245 | AHU Rm 12-13 Girls Room | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | State St Elementary-5305 | 304246 | AHU Rm 20+21 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | State St Elementary-5305 | 304247 | AHU Rm 20+21 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | State St Elementary-5305 | 304248 | Custodial Closet #9 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | Ward High School-5305 | 304140 | EF #5 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | Ward High School-5305 | 304160 | CEX # 6 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | Ward High School-5305 | 304175 | ACCU # 9 | Air Conditioner Pkg | AHU Hot Deck |
| Westerly Public Schools | Ward High School-5305 | 304176 | Condenser Unit | Air Conditioner Pkg | AHU Hot Deck |
| Westerly Public Schools | Ward High School-5305 | 304180 | LEX #2 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | Ward High School-5305 | 304181 | LEX #1 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | Ward High School-5305 | 304184 | Ex Fan | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | Ward High School-5305 | 304185 | EF #12 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | Ward High School-5305 | 304187 | ERU -2 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | Ward High School-5305 | 304188 | ERU -1 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | Ward High School-5305 | 304196 | BEX 5 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | Ward High School-5305 | 304202 | CU-1 | Air Conditioner Pkg | AHU Hot Deck |
| Westerly Public Schools | Ward High School-5305 | 304203 | ACCU -10 | Air Conditioner Pkg | AHU Hot Deck |
| Westerly Public Schools | Ward High School-5305 | 304170 | RTU #2 | Air Dist Ventilation | AHU H/C Pkg Gas 2-10Ton |
| Westerly Public Schools | Ward High School-5305 | 304195 | AHU | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | Ward High School-5305 | 304125 | BFP #1 | Water System | Backflow Preventer |
| Westerly Public Schools | Ward High School-5305 | 304134 | BFP #2 | Water System | Backflow Preventer |
| Westerly Public Schools | Ward High School-5305 | 304138 | ACCU # 11 | Air Conditioner Pkg | Condensing Unit General |

| Client Name | Building Name | Tag # | Description | Type Desc | Subtype Desc |
|-------------------------|-----------------------------|--------|----------------|----------------------|-------------------------|
| Westerly Public Schools | Ward High School-5305 | 304178 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General |
| Westerly Public Schools | Ward High School-5305 | 304197 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General |
| Westerly Public Schools | Ward High School-5305 | 304135 | EF #17 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304136 | EF #8 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304137 | EF #7 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304139 | EF #18 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304141 | EF #6 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304155 | EF #4 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304156 | EF #3 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304157 | CEX #8 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304158 | CEX #7 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304159 | CEX #5 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304162 | CEX #4 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304163 | CEX #3 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304164 | CEX #2 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304165 | CEX #1 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304167 | EF #1 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304168 | EF #11 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304169 | EF #2 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304171 | LCEX #3 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304172 | LCEX #1 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304173 | EX #1 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304174 | EF #12 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304177 | LEX #3 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304186 | EF 3 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304194 | EF-2 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304198 | BEX 3 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304199 | BEX 2 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304200 | BEX 6 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304201 | EF-9 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Ward High School-5305 | 304189 | EF 5 | Air Dist Ventilation | Fan Exhaust Belt 1-5 HP |
| Westerly Public Schools | Ward High School-5305 | 304190 | EF 8 | Air Dist Ventilation | Fan Exhaust Belt 1-5 HP |
| Westerly Public Schools | Ward High School-5305 | 304191 | EF-6 | Air Dist Ventilation | Fan Exhaust Belt 1-5 HP |
| Westerly Public Schools | Ward High School-5305 | 304192 | EF-7 | Air Dist Ventilation | Fan Exhaust Belt 1-5 HP |
| Westerly Public Schools | Ward High School-5305 | 304193 | EF-4 | Air Dist Ventilation | Fan Exhaust Belt 1-5 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 303999 | RH-3 | Air Dist Ventilation | |
| Westerly Public Schools | Westerly Middle School-5305 | 304003 | RH-2 | Air Dist Ventilation | |
| Westerly Public Schools | Westerly Middle School-5305 | 304007 | EF-4 | Air Dist Ventilation | |
| Westerly Public Schools | Westerly Middle School-5305 | 304041 | Condenser Unit | Air Dist Ventilation | |
| Westerly Public Schools | Westerly Middle School-5305 | 304042 | Condenser Unit | Air Dist Ventilation | |

| Client Name | Building Name | Tag # | Description | Type Desc | Subtype Desc |
|-------------------------|-----------------------------|--------|----------------|----------------------|--------------------------|
| Westerly Public Schools | Westerly Middle School-5305 | 304059 | Condenser Unit | Air Conditioner Pkg | |
| Westerly Public Schools | Westerly Middle School-5305 | 304063 | Condenser Unit | Air Dist Ventilation | |
| Westerly Public Schools | Westerly Middle School-5305 | 304064 | Condenser Unit | Air Dist Ventilation | |
| Westerly Public Schools | Westerly Middle School-5305 | 304069 | Condenser Unit | Air Conditioner Pkg | |
| Westerly Public Schools | Westerly Middle School-5305 | 304071 | Condenser Unit | Air Conditioner Pkg | |
| Westerly Public Schools | Westerly Middle School-5305 | 304033 | Condenser Unit | Air Conditioner Pkg | (a) Under 3 Ton Split |
| Westerly Public Schools | Westerly Middle School-5305 | 304048 | Condenser Unit | Air Conditioner Pkg | (a) Under 3 Ton Split |
| Westerly Public Schools | Westerly Middle School-5305 | 304049 | Condenser Unit | Air Conditioner Pkg | (a) Under 3 Ton Split |
| Westerly Public Schools | Westerly Middle School-5305 | 304017 | RTU #5 | Air Dist Ventilation | AHU H/C Deck 2-10 Ton |
| Westerly Public Schools | Westerly Middle School-5305 | 304024 | RTU #6 | Air Dist Ventilation | AHU H/C Pkg Gas 2-10Ton |
| Westerly Public Schools | Westerly Middle School-5305 | 304030 | Trane Unit | Air Dist Ventilation | AHU H/C Pkg Gas 2-10Ton |
| Westerly Public Schools | Westerly Middle School-5305 | 304039 | Trane Unit | Air Dist Ventilation | AHU H/C Pkg Gas 2-10Ton |
| Westerly Public Schools | Westerly Middle School-5305 | 304050 | Trane Unit | Air Dist Ventilation | AHU H/C Pkg Gas 2-10Ton |
| Westerly Public Schools | Westerly Middle School-5305 | 304051 | RTU #10 | Air Dist Ventilation | AHU H/C Pkg Gas 2-10Ton |
| Westerly Public Schools | Westerly Middle School-5305 | 304052 | RTU #3 | Air Dist Ventilation | AHU H/C Pkg Gas 2-10Ton |
| Westerly Public Schools | Westerly Middle School-5305 | 304061 | Trane Unit | Air Dist Ventilation | AHU H/C Pkg Gas 2-10Ton |
| Westerly Public Schools | Westerly Middle School-5305 | 304070 | AHU-1 | Air Dist Ventilation | AHU Hot Cold Pkg |
| Westerly Public Schools | Westerly Middle School-5305 | 303996 | RTU #1 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | Westerly Middle School-5305 | 304009 | RTU #4 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | Westerly Middle School-5305 | 304019 | MUA-1 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | Westerly Middle School-5305 | 304058 | AHU-3 | Air Dist Ventilation | AHU Hot Deck |
| Westerly Public Schools | Westerly Middle School-5305 | 303997 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General |
| Westerly Public Schools | Westerly Middle School-5305 | 303998 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General |
| Westerly Public Schools | Westerly Middle School-5305 | 304000 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General |
| Westerly Public Schools | Westerly Middle School-5305 | 304002 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General |
| Westerly Public Schools | Westerly Middle School-5305 | 304005 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General |
| Westerly Public Schools | Westerly Middle School-5305 | 304011 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General |
| Westerly Public Schools | Westerly Middle School-5305 | 304020 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General |
| Westerly Public Schools | Westerly Middle School-5305 | 304027 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General |
| Westerly Public Schools | Westerly Middle School-5305 | 304028 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General |
| Westerly Public Schools | Westerly Middle School-5305 | 304034 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General |
| Westerly Public Schools | Westerly Middle School-5305 | 304035 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General |
| Westerly Public Schools | Westerly Middle School-5305 | 304036 | Condenser Unit | Air Conditioner Pkg | Condensing Unit General |
| Westerly Public Schools | Westerly Middle School-5305 | 304062 | EF-3 | Air Dist Ventilation | Fan Air Curtain >1000CFM |
| Westerly Public Schools | Westerly Middle School-5305 | 304004 | Exhaust Fan | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304008 | EF-2 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304010 | EF-1 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304012 | EF-9 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304013 | EF-7 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304014 | EF-6 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |

| Client Name | Building Name | Tag # | Description | Type Desc | Subtype Desc |
|-------------------------|-----------------------------|--------|-------------|-----------------------|-------------------------|
| Westerly Public Schools | Westerly Middle School-5305 | 304015 | EF-5 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304021 | EF-11 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304022 | EF-16 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304026 | EF-17 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304029 | EF-18 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304032 | EF-19 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304038 | EF-21 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304040 | EF-22 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304043 | EF-26 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304044 | EF-23 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304046 | EF-24 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304047 | EF-25 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304053 | EF-13 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304054 | EF-28 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304057 | EF-27 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304060 | Exhaust Fan | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304066 | EF-15 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304068 | EF-14 | Air Dist Ventilation | Fan Exhaust Belt 0-1 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304001 | EF-8 | Air Dist Ventilation | Fan Exhaust DirDrvo-1HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304023 | EF-12 | Air Dist Ventilation | Fan Exhaust DirDrvo-1HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304031 | EF-20 | Air Dist Ventilation | Fan Exhaust DirDrvo-1HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304072 | RAF#1 | Air Dist Ventilation | Fan Return Belt 1-5 HP |
| Westerly Public Schools | Westerly Middle School-5305 | 304073 | A- CHW #1 | Cooling Chilled Water | Pump Elec Centrifugal |
| Westerly Public Schools | Westerly Middle School-5305 | 304074 | A- CHW #2 | Cooling Chilled Water | Pump Elec Centrifugal |
| Westerly Public Schools | Westerly Middle School-5305 | 304075 | B - CHW #1 | Cooling Chilled Water | Pump Elec Centrifugal |
| Westerly Public Schools | Westerly Middle School-5305 | 304076 | B - CHW #2 | Cooling Chilled Water | Pump Elec Centrifugal |
| Westerly Public Schools | Westerly Middle School-5305 | 304077 | C- CHW #1 | Cooling Chilled Water | Pump Elec Centrifugal |
| Westerly Public Schools | Westerly Middle School-5305 | 304078 | C- CHW #2 | Cooling Chilled Water | Pump Elec Centrifugal |
| Westerly Public Schools | Westerly Middle School-5305 | 304025 | Chiller | Cooling Chiller | RCRR (a) Air 0-40 Ton |
| Westerly Public Schools | Westerly Middle School-5305 | 304037 | Chiller | Cooling Chiller | RCRR (a) Air 0-40 Ton |
| Westerly Public Schools | Westerly Middle School-5305 | 304045 | Chiller | Cooling Chiller | RCRR (a) Air 0-40 Ton |

RFQ 2022-033 Bid Form

| Location | Scope | School Total |
|--------------------|---------------|--------------|
| BH | See Exhibit A | |
| DCS | See Exhibit A | |
| SES | See Exhibit A | |
| SSS | See Exhibit A | |
| WMS | See Exhibit A | |
| WHS | See Exhibit A | |
| Transition Academy | See Exhibit A | |

Shipping/ Logistics/ Rigging
 Bonds
 Permits
 Total Project Cost

| |
|--|
| |
| |
| |
| |